

Certificate of Compliance

Certificate: 2240891

Master Contract: 248614

Project: 2240891


Date Issued: November 13, 2009

Issued to: Athlon Generator LLC
15885B Kings Highway
Montross, VA 22520
USA

*The products listed below are eligible to bear the CSA Mark shown
With adjacent indicators 'C' and 'US' for Canada and US or with adjacent
indicator 'US' for US only or without either indicator for Canada only*



Issued by: K. Atkins



Authorized by: Len Candeloro
Product Group Manager

PRODUCTS

CLASS 4211 01 - MOTORS AND GENERATORS

CLASS 4211 81 - MOTORS AND GENERATORS - CERTIFIED TO U.S. STANDARDS

Three-phase Brushless Alternator, Self Excited, 60 Hz, Insulation Class H, 0.8 Power Factor, 40 °C Ambient, AG Series. Model No and ratings as follows:

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No.0-M91	-	General Requirements – Canadian Electrical Code, Part II
CAN/CSA-C22.2 No.0.4-04	-	Bonding of Electrical Equipment
CSA-C22.2 No.100-04	-	Motors and Generators
ANSI/UL 1004-1 1 st Edition	-	Rotating Electrical Machines – General Requirements
ANSI/UL 1004-4 1 st Edition	-	Electric Generators

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.